



AZZO TILE AND ARCHITECTURAL PRODUCTS SOLUTIONS, LLC.
PO BOX 1063 FORT LEE, NJ, 07024 (USA)
Phone: (201)-731-4249
e-mail: azzotile@gmail.com

**TERRAZO TILES FOR INDOORS-SLIP
RESISTANCE UNE EN 1341 Anexo D**

File number:	EH-100602	Sample number:	140150/2
Customer:	AZZO TILE AND ARCHITECTURAL PRODUCTS SOLUTIONS, LLC.		
Address:	PO BOX 1063 FORT LEE, NJ, 07024 (USA)		
Work:	Self-Control Production-C.E Labelled		
Sample:	Monolayer Terrazo Tile of 16 x 16 x 0.8 in SURFACE: Polished (Factory)		
Origin:	Factory		
Reception date:	01/10/2015	Test Date:	01/16/2015

LENGTH TEST AREA:

126 mm / 4.96 in

SAMPLE 1

Test nr	Test Value	Test Value 180°	Average Value
1	31	32	31.5
2	27	29	28
3	25	27	26
4	24	25	24.5
5	26	24	25
USRV SAMPLE			27

SAMPLE 2

Test nr	Test Value	Test Value 180°	Average Value
1	32	31	31.5
2	33	27	30
3	31	25	28
4	29	24	26.5
5	27	26	26.5
USRV SAMPLE			29

SAMPLE 3

Test nr	Test Value	Test Value 180°	Average Value
1	35	33	34
2	30	28	29
3	29	26	27.5
4	26	25	25.5
5	27	26	26.5
USRV SAMPLE			29

SAMPLE 4

Test nr	Test Value	Test Value 180°	Average Value
1	29	32	30.5
2	28	30	29
3	28	31	29.5
4	27	26	26.5
5	25	26	25.5
USRV SAMPLE			28

Average USRV Sample Value

28

CERTIFICATIONS:

QUALITY



ENVIRONMENT

